

## High Performance and Efficiency

- 750 Gallons Per Day
- 96%+ Rejection of Total Dissolved Solids
- 1 to 2.50 Waste to Product Water Ratio



# AXEON HYDRO RO-SERIES

High-Efficiency Hyperfiltration System

[AXEONWATER.COM](http://AXEONWATER.COM)





## SPECIFICATIONS

Flow Rate <sup>A</sup> (gpd)	750
Rejection Rate (%)	96+
Efficiency Rate	See Chart Below
Sediment Filter Change (Months)	3 - 6
Carbon Filter Change (Months)	3 - 6
HyperFilter Change (Months)	6 - 12
Voltage	100 - 240V, 50 / 60 HZ, 1 PH, 1.0A
Dimensions L x W x H (in)	16 x 9 x 27
Dry Weight (lbs)	20.5



## OPERATING LIMITS<sup>B</sup>

AXEON® HYDRO – 750   Expected Flow Rates					
Inlet Pressure (psi)	Gallons Per Day (gpd)	Gallons Per Hour (gph)	Product Water to Waste Ratio		Recovery Rate %
40	375	15.63	1.10	1	52%
50	450	18.75	1.60	1	61%
60	550	22.92	1.95	1	66%
70	650	27.08	2.25	1	69%
80	750	31.25	2.50	1	71%

gpd = gallons per day, gph = gallons per hour

Design Temperature (°F / °C)	77 / 25	Minimum Feed Pressure (psi / bar) <sup>C</sup>	40 / 2.76
Maximum Feed Temperature (°F / °C)	85 / 29	Maximum Feed Silt Density Index (SDI)	< 3
Minimum Feed Temperature (°F / °C)	40 / 4	Maximum Turbidity (NTU)	1
Maximum Ambient Temperature (°F / °C)	120 / 49	Maximum Free Chlorine (ppm)	< 1
Minimum Ambient Temperature (°F / °C)	40 / 4	Maximum TDS (ppm)	600
Maximum Feed Pressure (psi / bar) <sup>C</sup>	100 / 6.89	Maximum Hardness (gpg)	< 1

A. Low temperatures and feedwater quality, such as high TDS levels, will significantly affect the system's production capabilities and performance. Use on microbiologically safe water only and follow all state and federal plumbing and electrical codes.

B. If any of the feed water parameters are not within the limits given, consult your local dealer or distributor for assistance.

C. System operating pressure is based on 40 psi feed pressure, minimum concentrate flow as stated, and an average of 375 GPD flow per membrane at 77 °F / 25 °C.

Warranty Evaluation Test Conditions: Permeate flow rates and salt rejection based on the following test conditions – 550 ppm, filtered and dechlorinated municipal tap water, 77 °F / 25 °C, 15% recovery, 7.0 pH and the specified operating pressure for membrane element type. Data taken after 60 minutes of operation.